

## **Electrical Inspections & test requirements**

- 1 Periodicity inspections are done of house ( Mc gill electrical, Dundee )
- 2 resistance checks about 20% of factory checked only when doing faults
- 3 0% resistance checks on sockets /new sockets checked
- 4 lighting checked yearly ,along with emg lights
- 5 Formal inspections 18 mths ago (Mc gill electrical )
- 6 Shutdown fab 18 mths ago (Mc gill electrical ) mains supply ie knives 10 year check.going to 5 years  
?
- 7 No down time on tools due to workload !

Alan Dingwall  
Compugraphics